

Comment: A temporary solution could include increasing the capacity of the pumps at the Federal Project to allow us to take water when the fish are not adversely affected.

The maximum capacity of the Federal Pumps is physically constrained by the pumps themselves, the canals and the fish facilities. The Project is already run at maximum capacity as often as the hydrologic, biological and storage in San Luis Reservoir conditions allow.